



ठाणे महानगरपालिका, ठाणे.

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग, चंदनवाडी पांचपाखाडी, ठाणे ४०० ६०२.

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

Ref/T.M.C./CFO/M - 30

Date - 11/07/2024

FIRE SAFETY CERTIFICATE

Certified that the ARUNODAYA PUBLIC SCHOOL (name of the building or Premises) at Vijay Park, G.B.Road, Kasarwadavali, Thane (w) 400615, (address) Comprised of Ground Floor + 1st Floor (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 11/07/2024 (date of inspection) in the presence of FYRE SOLUTION (name and addresses of the Manager/ Secretary or his representative) and that the building / premises is fit for occupancy up to classes Nursery to (X/XII) With effect from 11.06.2024 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

- | | | | |
|--|-------|-------------------|-------|
| 1. Fire Extinguisher ABC Type 2,4,5, & 9kg | - Yes | 5. Smoke Detector | - Yes |
| 2. Fire Extinguisher - CO2- 01kg & 4.5kg | - Yes | 6. Heat Detector | - Yes |
| 3. Fire Bucket | - Yes | 7. MCP | - Yes |
| 4. Fire Alarm Panel | - Yes | 8. Hooter | - Yes |

Issued on 11/06/2024 (date of issue) at Thane (place) by

Signature with seal: _____

Name : Mr. Girish. M. Zalke

Designation : Chief Fire Officer, Thane

Name & Address of Department/ Office : Chief Fire Officer, Thane
Municipal Fire Brigade, Thane.



To

ARUNODAYA PUBLIC SCHOOL
Vijay Park, G.B.Road, Kasarwadavali,
Thane (w) 400615.
(Name & Address of the Institution)

ENDORSEMENT

The no objection certificate issued by Fire Service stand cancelled and annulled due to negligence of any fire safety norms laid by state government.

This Fire Safety Certificate Subject to Submission of Form B For Every Six Month as per Maharashtra Fire Prevention & Life Safety Act 2006.

(Name and designation of the authorized signatory)